

Key to Detected Contaminants Tables

Symbol	Abbreviation for	Definition/Explanation
MCLG	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
MCL	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MRDLG	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	Maximum Residual Disinfectant Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
ppb	Parts per billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
ppm	Parts per million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
NTU	Nephelometric Turbidity Units	Measures the cloudiness of water.
TT	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
pCi/L	Picocuries per liter	A measure of radioactivity. Picocuries (pCi) means the quantity of radioactive material producing 2.22 nuclear transformations per minute.
AL	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAA5	Haloacetic acids	HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
TTHM	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane, and bromoform. Compliance is based on the total.
n/a	Not applicable	
>	Greater than	

Important Health Information - Lead

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Flushing is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure, is available from the Safe Drinking Water Hotline at (800) 426-4791, or at <http://www.epa.gov/safewater/lead>.

Your source water comes from the lower Lake Huron watershed. The watershed includes numerous short, seasonal streams that drain to Lake Huron. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is a seven-tiered scale ranging from very low to very high based primarily on geologic sensitivity, water chemistry, and contaminant sources. The Lake Huron source water intake is categorized as having a moderately low susceptibility to potential contaminant sources. The Lake Huron water treatment plant has historically provided satisfactory treatment of this source water to meet drinking water standards.

In 2015, DWSD received a grant from The Michigan Department of Environmental Quality to develop a source water protection for the Lake Huron water treatment plant intake. The program includes seven elements that include the following: roles and duties of government units and water supply agencies, delineation of a source water protection area, identification of potential of water source water protection area, management approaches for protection, contingency plans, siting of new sources and public participation. If you would like to know more information about the Source Water Assessment report or a complete copy of this report please contact DWSD/GLWA (313) 926-8102.

If you would like more information about this report, or a copy of this report, please contact your water department at (810) 659-5665, as individual reports will not be mailed out.

CITY OF FLUSHING

**2015 Water Quality Report
for the
City of Flushing**

725 E. Main Street • Flushing, MI 48433

This report covers the drinking water quality for the City of Flushing for the calendar year 2015. This information is a snapshot of the quality of the water that we provided to you in 2015. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

The City of Flushing is supplied by surface water pumped from Lake Huron and delivered to us through the Genesee County water supply system.

Contaminants and their presence in water:

Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.

Vulnerability of some populations:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- T **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- T **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- T **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- T **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
- T **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which provide the same protection for public health.

The table below lists all the drinking water contaminants that were detected during the 2015 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 - December 31, 2015. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

This report is available for public review at the city offices, 725 E. Main Street, Flushing, Michigan 48433.

Regulated Contaminant	Test Date	Units	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Inorganic Chemicals - Annual Monitoring at Plant Finished Water Tap								
Fluoride	05/11/2015	ppm	4	4	0.43	n/a	No	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5/11/2015	ppm	10	10	0.3	n/a	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Combined radium Radium 226 & 228	5/13/2014	pCi/L	0	5		0.86 +/- 0.55	No	Erosion of natural deposits
Disinfectant Residuals and Disinfection By-Products - Monitoring in Distribution System								
Total Trihalomethanes (TTHM)	Aug. 2015	ppb	n/a	80	48.6	48.6	no	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	Aug. 2015	ppb	n/a	60	16	16	No	By-product of drinking water disinfection
Disinfectant (Total Chlorine residual)	Jan-Dec 2015	ppm	MRDGL 4	MRDL 4	1.3	0.20-1.3	No	Water additive used to control microbes

2015 Turbidity - Monitored every 4 hours at Plant Finished Water Tap			
Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water
0.20 NTU	100%	No	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.			

2015 Microbiological Contaminants - Monthly Monitoring in Distribution System					
Contaminant	MCLG	MCL	Highest Number Detected	Violation yes/no	Major Sources in Drinking Water
Total Coliform Bacteria	0	Presence of Coliform bacteria >5% of monthly samples	0	No	Naturally present in the environment.
<i>E. coli</i> or fecal coliform bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E. coli</i> positive.	0	No	Human waste and animal fecal waste.

2014 Lead and Copper Monitoring at Customers' Tap								
Contaminant	Test Date	Units	Health Goal MCLG	Action Level AL	90th Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2014	ppb	0	15	2.5 ppb	0	No	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2014	ppb	1300	1300	170 ppb	0	No	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.

*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

Regulated Contaminant	Treatment Technique	Running annual average	Monthly Ratio Range	Violation yes/no	Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal.				Erosion of nature deposits

2015 Special Monitoring

Contaminant	MCLG	MCL	Level Detected	Source of Contamination
Sodium (ppm)	n/a	n/a	4	Erosion of natural deposits

Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants. Beginning in July of 2008, the Detroit Water and Sewerage Department (DWSD) began monitoring quarterly for unregulated contaminants under the Unregulated Contaminant Monitoring Rule 2 (UCMR3).